

JUNE 2026 TCCWD Board Cover Sheet

Timber Cove County Water District #4900584

Alfonzo Portugal III, Chief Operator

Licensed: D2/T2

22098 Lyons Ct., Jenner, CA., 95450

Mat

Sa

Division of

50 D Street #200, Santa R

	Gallons	% of Usable Water
Reservoir-to-Plant Production:	434,210	100.00%

Metered Water Usage:

Timber Cove Resort usage:	91,349	21.04%
Residential usage:	148,740	34.26%
Commercial Meter usage:	0	0.00%
Manual water Meter usage:	306	0.07%
Total Metered Water Use(gallons):	240,395	55.36%

Non-Billable Operational Usage:

TCCWD Office usage:	241	0.06%
Backwash Water Usage:	26,897	6.19%

Non-Billable Distribution Usage:

Hydrant Flushing for the Month:	26,147	6.02%
Total Gallons Used for the month:	293,680	67.64%

<u>Unaccountable, non-billable water loss:</u>	140,530	32.36%
---	----------------	---------------

RESERVOIR:

Operational water returned-to-Reservoir:	76,270
Weir-to-Reservoir Meter(gallons):	848,654
Total Gallons to Reservoir for June:	924,924

Reservoir Level at the end of June 2026:

St Foster, PE

Sanitary Engineer

Drinking Water

Los Angeles, CA 95404

Average

gpd

14,474

3,045

4,958

0

10

8

24'11"