

MAY 2026 TCCWD Board Cover Sheet

Timber Cove County Water District #4900584

Alfonzo Portugal III, Chief Operator
Licensed: D2/T2
22098 Lyons Ct., Jenner, CA., 95450

Matt Foster, PE
Sanitary Engineer
Division of Drinking Water
50 D Street #200, Santa Rosa, CA 95404

	Gallons	% of Usable Water	Average gpd
Reservoir-to-Plant Production:	385,748	100.00%	12,443

Metered Water Usage:

Timber Cove Resort usage:	81,169	21.04%	2,618
Residential usage:	179,804	46.61%	5,800
Commercial Meter usage:	909	0.24%	29
Manual water Meter usage:	620	0.16%	20
Total Metered Water Use(gallons):	262,502	68.05%	

Non-Billable Operational Usage:

TCCWD Office usage:	745	0.19%	24
Backwash Water Usage:	19,353	5.02%	

Non-Billable Distribution Usage:

Hydrant Flushing for the Month:	15,459	4.01%
Total Gallons Used for the month:	298,059	77.27%

Unaccountable, non-billable water loss: **87,689** 22.73%

RESERVOIR:

Operational water returned-to-Reservoir:	48,620
Weir-to-Reservoir Meter(gallons):	356,415
Total Gallons to Reservoir for May:	405,035

Reservoir Level at the end of May 2026: 24'9"