

JANUARY 2026 TCCWD Board Cover Sheet

Timber Cove County Water District #4900584

Alfonzo Portugal III, Chief Operator
 Licensed: D2/T2
 22098 Lyons Ct., Jenner, CA., 95450

Matt Foster, PE
 Sanitary Engineer
 Division of Drinking Water
 50 D Street #200, Santa Rosa, CA 95404

| | Gallons | % of Usable Water | Average gpd |
|--------------------------------|----------------|--------------------------|--------------------|
| Reservoir-to-Plant Production: | 377,407 | 100.00% | 12,174 |

Metered Water Usage:

| | | | |
|--|----------------|---------------|-------|
| Timber Cove Resort usage: | 90,394 | 23.95% | 2,916 |
| Residential usage: | 165,406 | 43.83% | 5,336 |
| Commercial Meter usage: | 0 | 0.00% | 0 |
| Manual water Meter usage: | 29 | 0.01% | 1 |
| Total Metered Water Use(gallons): | 255,829 | 67.79% | |

Non-Billable Operational Usage:

| | | |
|-----------------------|--------|-------|
| TCCWD Office usage: | 0 | 0.00% |
| Backwash Water Usage: | 21,127 | 5.60% |

Non-Billable Distribution Usage:

| | | |
|--|----------------|---------------|
| Hydrant Flushing for the Month: | 1,727 | 0.46% |
| Total Gallons Used for the month: | 278,683 | 73.84% |

Unaccountable, non-billable water loss: **98,724** 26.16%

RESERVOIR:

| | |
|--|---------------|
| Operational water returned-to-Reservoir: | 47,325 |
| Weir-to-Reservoir Meter: | 0 |
| Total Gallons to Reservoir for January: | 47,325 |

Reservoir Level at the end of January 2026: 24.2'